

EXHIBIT 9

FACILITY STANDARDS FOR MUTUAL WATER COMPANIES FORMED AFTER ENTRY OF JUDGMENT

For mutual water companies formed after entry of Judgment, all mutual water company infrastructure shall be constructed to meet Federal/State/County of San Diego/American Waterworks Association (AWWA) potable and recycled/non potable standards in effect at time of infrastructure construction, including but not limited to the following:

- Health & Safety Code section 116527 (Requirements and Compliance with the California Safe Drinking Water Act), as applied to “public water systems” defined in Health & Safety Code section 116275.
- California Code of Regulations, Title 22 section 64551 et seq., as applied to “public water systems” (California Waterworks Standards).
- Health & Safety Code section 116815, to include purple piping for recycled/non potable water systems.
- AWWA PVC Pipe-Design and Installation, Manual M23.
- AWWA PE Pipe – Design and Installation, Manual M55.
- C502-54: AWWA Standard Specifications for Fire Hydrants for Ordinary Water Works Service.
- C503-88: AWWA Standard for Wet-Barrel Fire Hydrants (California-type).
- County of San Diego Consolidated Fire Code (“County Code”) requirements, including those related to fireflow as applicable (County Code, sections 96.1.507.3 and 96.1.507.5.7, referencing Cal. Fire Code, sections 507.3 and 507.5.7).